

**LYNN WATER AND SEWER COMMISSION
400 PARKLAND AVE
LYNN, MASSACHUSETTS**

TO: All Bidders of Record

Date Issued: January 17, 2020

FROM: Betty Sutherland-Dumas, Chief Procurement Officer

BID OPENING DATE: Thursday, January 23, 2020 AT 11:00 A.M. E.S.T.

LOCATION OF BID OPENING: LYNN WATER AND SEWER COMMISSION
400 PARKLAND AVE.
LYNN, MA 01905
(781-596-2400)

**BID #20-003
PURCHASE OF ONE NEW CHLORINE DIOXIDE GENERATOR
FOR THE LYNN WATER TREATMENT PLANT**

**CONTRACT DOCUMENTS
ADDENDUM NO. 1**

TO ALL PLAN HOLDERS OF RECORD:

THE FOLLOWING INFORMATION AND ATTACHMENT IS NECESSARY TO PROPERLY PREPARE BIDS:

Firms submitting bids for the above bid shall take note of the following changes, additions, deletions, clarifications, etc. in the Bid Documents, which shall become part of and have precedence over anything contrarily shown or described in the Bid Documents, all such shall be taken into consideration and be included in the bidder's bid.

GENERAL:

This document comprises **Addendum No. 1** to the above referenced project and shall be part of the Contract Documents and must be acknowledged on proper bid form page 00410-1 and submitted with bid. Instructions below shall supersede any contradictory instructions in the Contract Bid Documents.

The following is a summary of written questions received and response:

1. QUESTION: On the bid spec for 36-month service, it states 8 service visits. Is that 8 total over 36 months, or 8 per year, or some other sequence?

ANSWER: This question refers to Specification Section 11266 Section 3.06 36-MONTH SERVICE CONTRACT (BID ITEM 2). The Chlorine Dioxide Generator Manufacturer shall include a **total** of eight (8) service visits over a 36-month period to be used at the Owner's discretion as part of the base service contract.

END OF ADDENDUM NO. 1